

UNIVERSITY OF NEW HAMPSHIRE
CONSTRUCTION AND RENOVATION STANDARDS

DIVISION 4 - MASONRY

SECTION 04200 - UNIT MASONRY

PART 2 - PRODUCTS

1. Face brick shall be standard size, red water-struck brick or equal to match brick used throughout campus. When working on existing buildings match surrounding brick, mortar color and coursing.
2. Hot lime mortar shall be used for exterior masonry.
3. Masonry sealer shall be Dupont or equal.
4. Red water-struck brick shall be

PART 3 - EXECUTION

1. Wash down of equipment used for mixing, storing or moving mortar shall be in such a location that the residue will not be a problem for future landscaping, excavation, underground drainage systems, etc. No wash down shall occur near or into new or existing sanitary or storm drainage lines.

END OF SECTION