

UNIVERSITY OF NEW HAMPSHIRE
CONSTRUCTION AND RENOVATION STANDARDS

SECTION 07500 - ROOFING AND FLASHING

PART 1 - GENERAL

1. All roofs shall be fully adhered/mechanically fastened. Ballasted roofing systems are not acceptable.
2. All exposed copper flashing, gravel stops, expansion joints, etc. shall be lead coated. Use Revere Copper publications and specifications as a guide for use of copper.

PART 2 - PRODUCTS

1. Lead coated flashing shall be Revere Lead Tex 15 or equal.

END OF SECTION