

UNIVERSITY OF NEW HAMPSHIRE  
CONSTRUCTION AND RENOVATION STANDARDS

SECTION 08200 - WOOD DOORS

PART 1 - GENERAL

1. Wood doors, transoms and frames shall not be allowed for exterior doors.
2. Full length glass doors shall not be allowed.
3. **All** wood door edges on latchside, shall be beveled 1/8" on 2".
4. Minimum Width – Any door intended for passage by the public shall not be less than 36" in width.
5. Glazed Lites – Where doors are provided with glazed lites and do not have a transparent full length sidelite, the bottom edge of the lite shall be no more than 43" above finished floor and shall be glazed with transparent glazing material.

PART 2 - PRODUCTS

1. All flush type wood doors shall be solid lumber core equal to Weyerhaeuser #DFJ-1.
2. Wood fire rated doors shall be green dowel fire mineral core equal to Weyerhaeuser #DFM-90, DFM-60, DFM-45 as required. Reinforce mineral core doors as needed to receive surface applied hardware. Through bolts are not acceptable.
3. All wood doors with glass and all panel doors shall have 6" minimum stiles and midrails, and 8" minimum top and bottom rails. Align midrail location with exit devices and push bars; all exit devices and push bars on doors with greater than 1/2 glass shall be located behind a midrail.
4. All wood doors shall be 1-3/4 " thick.

END OF SECTION