

UNIVERSITY OF NEW HAMPSHIRE
CONSTRUCTION AND RENOVATION STANDARDS

DIVISION 9 - FINISHES

SECTION 09200 - LATH AND PLASTER

PART 2 - PRODUCTS

1. Soft plaster ceiling shall not be used.
2. Plaster used washrooms, showers, toilet areas, etc. shall be a cement plaster.
3. Renovations in **Stoke Hall** shall have sheetrock lath (wire lath is not acceptable).

PART 3 - EXECUTION

1. Wash down of equipment related to plastering should be off the site or in such a location that the residue will not be a problem for future landscaping, excavation, underground drainage systems, etc. No wash down shall occur near or into new or existing sanitary or storm drainage lines.

END OF SECTION