

UNIVERSITY OF NEW HAMPSHIRE
CONSTRUCTION AND RENOVATION STANDARDS

SECTION 10520 - FIRE EXTINGUISHERS, CABINETS AND ACCESSORIES

PART 1 - GENERAL

1. Portable fire extinguishers, cabinets and accessories shall be by one manufacturer, unless otherwise acceptable to Owner or Director of Facilities Design and Construction.

PART 2 - PRODUCTS

1. UL-Listed Products: Provide new portable fire extinguishers which are UL-listed and bear UL "Listing Mark" for type, rating, and classification of extinguisher indicated.
2. FM Listed Products: Provide new fire extinguishers which are approved by Factory Mutual Research Corporation for type, rating, and classification of extinguisher indicated and carry appropriate FM marking.

PART 3 - EXECUTION

1. Fire extinguishers, cabinets and accessories shall be supplied and installed to comply with applicable requirements of the following standards. Where these standards conflict with other specified requirements, the most restrictive requirements shall govern.
 - a. National Fire Protection Association (NFPA):
10 Portable Fire Extinguishers
 - b. National Association of Architectural Metal Manufacturers (NAAMM):
Ref. 1 Metal Finishing Manual

END OF SECTION