

UNIVERSITY OF NEW HAMPSHIRE  
CONSTRUCTION AND RENOVATION STANDARDS

SECTION 16485 - CONTACTORS

PART 1 - GENERAL

1. Magnetic contactor for remote control of area lighting shall be mechanically held with coil clearing contacts of amperage rating required. Contactor shall be incorporated in panel by panel-board manufacturer. Contactors shall be controlled with momentary contact switches.

PART 2 - PRODUCTS

1. Magnetic contactors lighting and heating:
  - ASCO - Bulletin 920
  - ITE - Bulletin 920 - Siemens
  - General Electric
  - ABB/Westinghouse/Cutler Hammer
  - Furnas
  - Square D
2. Magnetic motor starters:
  - General Electric
  - ABB/Westinghouse/Cutler Hammer
  - ITE - Siemens
  - Furnas
  - Square D

END OF SECTION